

PT. Chitose Internasional Tbk Quality Control (QC)	HASIL UKUR INTENSITAS CAHAYA DI LOKASI INSPEKSI QC	No.	Dibuat oleh	Revisi	Disetujui oleh	Tgl. Efektif
		1	CO of QC	△	QC Asst. Mgr	17-07-18
		2		△		
		3		△		
No : CINT/QC/F-034/HUICDLIQC						



Hari, Tanggal : Selasa / 02 - 04 - 2024

NO.	AREA INSPEKSI	STANDAR LUX	HASIL UKUR (MIN ~ MAX)		HASIL (OK/NG)	KETERANGAN
1	Receiving	750	746	765	OK	
2	Assembling Folding Line 2	750	743	749	OK	
3	Assembling Folding Line 3	750	695	752	OK	
4	Assembling Multy Line 1	750	740	755	OK	
5	Assembling Multy Line 2	750	725	758	OK	
6	Assembling Multy Line 3	750	742	758	OK	
7	Assembling Special Order/NSB	750	840	915	OK	
8	Assembling Roland	750	1180	1300	OK	
9	Assembling Kawai	750	1120	1138	OK	
10	Assembling Multy Baros	750	1557	1642	OK	
11	Finishing Chrome Depan	750	739	758	OK	cahaya dari luar
12	Finishing Chrome Belakang	750	958	1057	OK	- " -
13	Finishing Powder Coating/Cat	750	1510	1760	OK	- " -
14	Wood line	750	748	754	OK	- " -
15	Line C-PTO	750	745	750	OK	- " -
16						
17						
18						
19						
20						
21						
22						
23						
24						
25						
26						
27						
28						
29						
30						

Cimahi, Tgl. 02 - 04 - 2024

Diukur oleh,
Ferri-P
(Ferri-P)

Mengetahui,
[Signature]